


<b>CITY AND COUNTY OF DENVER</b>	<b>POLICY</b>	<b>DENVER FIRE DEPARTMENT</b>
Subject: <b>MARIJUANA ESTABLISHMENTS OR BUSINESSES</b>		
Reference: <b>2011 Denver Fire Code (DFC)</b>		
Approved:  Joseph L. Gonzales, Division Chief, Fire Prevention Division		
Number: <b>DFC 105.6</b>	Effective Date: <b>March 9, 2014</b>	Page <b>1</b> of <b>5</b>

**This policy is meant to provide basic information for most common conditions and situations. In any given occupancy, all other Fire Code requirements will be enforced. The Fire Inspector will address these during a premises inspection. Questions can be addressed by contacting the Fire Prevention Division between 6:30 a.m. and 4:30 p.m. at 720-913-3474 or at [FLAMMABLES@DENVERGOV.ORG](mailto:FLAMMABLES@DENVERGOV.ORG)**

## **I. SCOPE**

This policy shall apply to all marijuana establishments or businesses licensed by Denver Excise and Licenses, including but not limited to marijuana-infused product operations, marijuana cultivation, testing labs, and marijuana sales occupancies located within the City and County of Denver. These establishments or businesses involve unique operations which create significant life safety and fire hazards. As such, all establishments or businesses engaging in these activities shall be required to obtain all applicable annual operational permits from the Denver Fire Department – Fire Prevention Division.

New and/or existing unpermitted/non-compliant marijuana-related establishments or businesses may require construction permits or a change of occupancy; this may include access control systems, electrical modifications, addition or deletions of walls, modification to mechanical systems (exhaust hood systems), etc. Please see the Denver Fire Department *Guideline for Construction Permitting for Marijuana Establishments / Businesses Located in Commercial Buildings* for further information during the construction permitting process.

## **II. DEFINITIONS**

For the purposes of this policy, all marijuana-related terms are defined per the State of Colorado Marijuana Code 1 CCR 212.

## **III. PERMITS**

Upon Approval by Denver Fire Prevention Division personnel, annual operational permit(s) may be obtained from the Denver Fire Department. To obtain permits, contact the FLAMMABLES section at the Denver Fire Department – Fire Prevention Division located on the first floor of 745 West Colfax Avenue, Denver, Co. 80204 by telephone 720-913-3474 or via email at [FLAMMABLES@DENVERGOV.ORG](mailto:FLAMMABLES@DENVERGOV.ORG). **Permit hours are from 6:30 AM to 9:00 AM, Monday through Friday** (Holidays excepted). Checks

CITY AND COUNTY OF DENVER	POLICY	DENVER FIRE DEPARTMENT
Subject: <b>MARIJUANA ESTABLISHMENTS OR BUSINESSES</b>		
Number: <b>DFC 105.6</b>	Effective Date: <b>March 9, 2014</b>	Page <b>2</b> of <b>5</b>

should be made payable to: "Denver Manager of Finance." MasterCard, Visa and Discover are also accepted.

The following are the most common annual operational permits that may be needed at marijuana establishments or businesses:

- Annual Marijuana Establishment or Business Permit - (commercial occupancies)
- Annual LPG Use and Storage Permit - required for 1 pound or more of propane or butane (i.e. extractions)
- Annual CO<sub>2</sub> Enrichment System Permit – Including natural gas generators and for any system containing more than 100 lbs. of CO<sub>2</sub>
- Annual Compressed Gas Use and Storage Permit - required for 6,000 cu/ft or more of an inert. (1 pound of CO<sub>2</sub> = 8.74 cu/ft)
- Annual Fumigation / Thermal Insecticide Fogging
- Annual Extraction Process Permit
- Annual Flammable and Combustible Liquids Use and Storage Permit

#### **IV. SPECIFIC REQUIREMENTS**

##### **1. Exiting and Security**

- Required minimum exit access shall be provided.
- Enhanced building security measures shall by no means impede egress for the facility's occupants or firefighters in the event of an emergency.
- Fire Department Key Access (Knox Box) shall be provided near the main entrance to the facility.
- Where electronic access control is in use, a Denver Building Department 3B permit is required for the installation of the access control system. See Denver Building Code Appendix L.
- Locking hardware on doors (interior or exterior) shall be in accordance with Building Code Policy 1008.1.9.
- Clear aisles shall be maintained through grow rooms in accordance with Denver Fire Code Chapter 10.

##### **2. Fire extinguishers**

- Portable fire extinguishers shall be provided within the facility, near exits.
- Travel distance to extinguishers shall not exceed seventy-five (75) feet of travel.
- Minimum extinguisher size permitted is 2A10BC. (IFC 906 & 906.1)

<b>CITY AND COUNTY OF DENVER</b>	<b>POLICY</b>	<b>DENVER FIRE DEPARTMENT</b>
Subject: <b>MARIJUANA ESTABLISHMENTS OR BUSINESSES</b>		
Number: <b>DFC 105.6</b>	Effective Date: <b>March 9, 2014</b>	Page <b>3</b> of <b>5</b>

### **3. Graphic Map**

- An 8½" x 11" map displaying a general floor plan of the facility shall be provided near the main entrance in a clear protective cover for the cultivation facilities or where the floor plan of the building is complex and can confuse first responders during an emergency.

### **4. Interior Finishes / Building Construction**

- Hanging plastic films shall not be used to create walls, ceilings, or rooms. Where plastic films are applied to the walls or ceiling as an interior finish material, the installation shall comply with Chapter 8 of the Building Code. A Building Department construction permit maybe required for installation.

### **5. Premise Identification**

- Address numbers shall be posted per Denver Fire Code 505; minimum 6" numbers with minimum 0.75 stroke width on contrasting background

### **6. Electrical**

- Extension cords, power strips, or multi-outlet assemblies, etc., are prohibited from being used as permanent wiring.
- All electrical modification requires review and approval; permanent wiring (new circuits etc) requires an electrical permit from the Denver Building Department. Electrical panel load schedules (from engineered electrical permit drawings) shall be maintained on site.
- Emergency generators shall only be operated after obtaining permits from the Denver Building and Fire Departments.

## **V. SITE INSPECTION**

Upon approval of permit from the Denver Fire Department Fire Prevention Division, a Fire Inspector will conduct a field inspection of the site. Compliance with **all** Fire Code requirements shall be maintained at all times. Permit shall be kept on site and posted. Permit is valid only for the owner, time frame and site address indicated on the permit.

A permit may be revoked when:

1. Any of the conditions or limitations set forth in the permit have been violated
2. Compliance with written orders has not been achieved
3. False statements or misrepresentations of information provided in the permit application are found.

<b>CITY AND COUNTY OF DENVER</b>	<b>POLICY</b>	<b>DENVER FIRE DEPARTMENT</b>
Subject: <b>MARIJUANA ESTABLISHMENTS OR BUSINESSES</b>		
Number: <b>DFC 105.6</b>	Effective Date: <b>March 9, 2014</b>	Page <b>4</b> of <b>5</b>

4. The permit is issued in error or in violation of an ordinance, regulation or the Fire Code.

## **VI. NOTICE**

Any and all occupancies discovered operating marijuana establishments or businesses (including, but not limited to, marijuana-infused product operations, marijuana cultivation, testing labs, and marijuana sales occupancies) not in compliance with all requirements of the City and County of Denver and the requirements of this policy may result in the issuance of a "Stop Work Order" and a summons being issued to all offending parties.

<b>CITY AND COUNTY OF DENVER</b>	<b>POLICY</b>	<b>DENVER FIRE DEPARTMENT</b>
Subject: <b>MARIJUANA ESTABLISHMENTS OR BUSINESSES</b>		
Number: <b>DFC 105.6</b>	Effective Date: <b>March 9, 2014</b>	Page <b>5</b> of <b>5</b>

**MARIJUANA ESTABLISHMENTS OR BUSINESSES PERMIT APPLICATION**

Business Name: \_\_\_\_\_

Permit Site Address: \_\_\_\_\_

Business Phone: \_\_\_\_\_

Owner Name: \_\_\_\_\_

Owner Address: \_\_\_\_\_

Owner Phone: \_\_\_\_\_

Owner E-Mail: \_\_\_\_\_

Type of establishment or business (check all that apply):

- |  |   |
|--|---|
| <input type="checkbox"/> Retail Marijuana Store            | <input type="checkbox"/> Medical Marijuana Center                       |
| <input type="checkbox"/> Retail Marijuana Cultivation      | <input type="checkbox"/> Medical Marijuana Optional Premise Cultivation |
| <input type="checkbox"/> Retail Marijuana Product Manuf.   | <input type="checkbox"/> Medical Marijuana Infused Product              |
| <input type="checkbox"/> Retail Marijuana Testing Facility |   |

Type of processes performed onsite (check all that apply):

- |   |   |
|---|---|
| <input type="checkbox"/> Plant extractions            | <input type="checkbox"/> CO2 enrichment                           |
| <input type="checkbox"/> Compressed gas storage/use   | <input type="checkbox"/> Fumigation / Thermal Insecticide Fogging |
| <input type="checkbox"/> Flammable liquid storage/use | <input type="checkbox"/> LPG storage/use                          |

I HAVE READ AND UNDERSTAND THE DENVER FIRE DEPARTMENT POLICY REGARDING MARIJUANA ESTABLISHMENTS OR BUSINESSES. I FURTHER UNDERSTAND THAT A SITE INSPECTION WILL BE CONDUCTED BY DENVER FIRE PREVENTION PERSONNEL AND THAT PERMITS MAY BE REVOKED WITHOUT REFUND IF ANY FIRE/BUILDING CODE VIOLATIONS ARE DISCOVERED.

SIGNATURE: \_\_\_\_\_ DATE: \_\_\_\_\_

**END OF DOCUMENT**

---